

Purchasing Department

Purchasing Department P.O. Box 9534 Baton Rouge, LA 70813 Phone: (225) 771-4580 Fax: (225) 771-2026

Addendum Number 2 April 28, 2021

Recording Studio Conversion Southern University and A&M College Baton Rouge, Louisiana 70813

Bid # 10288A

10:30 A.M.

May 12, 2021

The following modifications to the referenced project shall be incorporated into the original specifications and/or plans, if applicable. Unless a change is specifically made by addendum, the specifications and/or plans as issued, shall govern.

Note: Vendors are required to acknowledge receipt of this addendum on the Louisiana Uniform Public Work Bid Form

Attachments:

Clarifications
Finish Pallets/Drawings

Linda A. Antoine-Director of Purchasina

ADDENDUM NUMBER 2 Southern University Recording Studio-Bid # 10288A

Items listed herein and attached are clarifications to existing documents provide for the reference project. Contractor shall consider this information to be part of the bid documents

1. Stretched Fabric Treatments. Keynotes 1, 2 & 27 call for Treatments 1, 2 and 3 respectfully. What are the differences between these different Treatments?

WSDG RESPONSE:

Keynote 1: simple insulation and fabric combination (no substrate), per listed details

Keynote 2: similar to keynote 1, but this is then mounted on a substrate (1/4" plywood) over an insulated 3.5" air cavity

Keynote 27: should connect to details 7 and 7 on A5.3 (not A5.4)- this fabric finish treatment is installed over 1x3 wood planks with a gap between planks (oriented vertically) over an insulated airspace.

Refer to document <u>191224 Southern University Palette V7.pdf</u> for this information.

2. Sheet A1.2, RCP calls for Control 121 to have stretched fabric treatments with Keynotes 9 & 10 in the center of the room. The ceiling treatments on each side at the 8'6" ceiling height does not have a Keynote designation. What stretched fabric treatment are these areas to have?

WSDG RESPONSE: refer to detail 5 / A5.4.

3. Sheet A5.2, detail 5 shows the stretched fabric trim located at the $\frac{1}{2}$ " pegboard instead of down where the fabric can be attached. Is there a reason for this as we attach the fabric into the trim?

WSDG RESPONSE: agree – clip could be located adjacent to treatment structure to ensure fabric covers 3/4" plywood, provided enough rigid structure is provided for the treatment support.

4. We need to know the gauge of the metal studs and steel joist located on Sheet A3.1, details 1, 2 & 3 and also the size of the steel joist.

WSDG RESPONSE: gauge to be confirmed by structural engineer or framing contractor. Absent that information, for pricing please assume 20 gauge and 6" for the ceiling joists (likely @ 12" o.c.).

Attachments:

Finish Palette V7; Drawing Sheets A0.1, A1.0, A1.1; A1.2; A1.3; A1.4; A2.3 and A4.1

END OF DOCUMENT



TECHNICAL INTERIOR DESIGN V7
PALETTE AND RENDERINGS

SOUTHERN UNIVERSITY

Baton Rouge, LA







ARCHITECTURAL ACOUSTIC CONSULTING | MEDIA SYSTEMS ENGINEERING

DECEMBER 24, 2019



SOUTHERN UNIVERSITY

PALETTE 01



GYPSUM WALL FINISH

SW 6254 LAZY GRAY SHERWIN WILLIAMS



ACOUSTIC TREATMENT -STRETCHED FABRIC

ICICLE 009 TEK-WALL BILLOW 399984 MAHARAM



ACOUSTIC TREATMENT -CASEWORK

PAINTED SW 2739 CHARCOAL BLUE SHERWIN WILLIAMS



ACOUSTIC TREATMENT - WOOD DIFFUSORS

MEDIUM CHERRY TO MATCH FLOORING



METAL DOORS

SW 7665 WALL STREET SHERWIN WILLIAMS



HARDWARE, KNOBS, PULLS

SATIN NICKEL



| GYPSUM CEILING FINISH -PAINT

SW 2534 ICY SHERWIN WILLIAMS



ACOUSTIC TREATMENT -STRETCHED FABRIC FOR

HARBOR 070 NETWORK 4158 GUILFORD OF MAINE



ACOUSTIC TREATMENT -DESK COUNTERTOP

LIMESTONE PRIMA CORIAN



| PLATFORM CARPET

SCRIPT - 965 STORY WEAVER INKLING C6383 MOHAWK GROUP



WOOD FLOOR

MAPLE GINGER - 60 LOCAL LEGACY STYLE EDITION MATCH FLOORING MOHAWK GROUP



WOOD TRIM

MEDIUM CHERRY TO

WSDG TECHNICAL INTERIOR DESIGN



SOUTHERN UNIVERSITY

RENDERINGS: CONTROL ROOM







WSDG TECHNICAL INTERIOR DESIGN



SOUTHERN UNIVERSITY

RENDERINGS: LIVE ROOM







WSDG TECHNICAL INTERIOR DESIGN